

### **DEPARTMENT OF TRANSPORTATION**

RICHMOND DISTRICT 2430 Pine Forest Drive COLONIAL HEIGHTS, VA 23834 www.VDOT.Virginia.gov

Charles A. Kilpatrick, P.E. COMMISSIONER

November 4, 2014

Mr.Lee Pambid County of Henrico P.O. Box 90775 Henrico, VA 23273

Re: West Broad Street Marketplace-Infrastructure and Mass grading

Mr. Pambid:

We have reviewed the plan for the above referenced project and have the following comments:

### **Sheet 3.01**

1. These plans will not be approved until plans for the proposed signal have been approved. Any offsite right of way or easements will need to be recorded prior to approval of this plan as well. Please show on the layout sheets where signal improvements and associated easements will be located. Please email a .pdf file of the signal plan revisions so that we may forward them to Traffic Engineering.

## Sheet 4.01/6.02

2. Please label public drainage easement. An easement is needed for any outfall the leaves VDOT r/w. The drainage easement could not be located. A drainage easement will need to be provided from the portions of structure 101 to outfall 99 which lies outside of the r/w.

# **Sheet 6.01**

3. Provide all CD-1, CD-2, UD-4, UD-3 on plans. Please change UD-1 to UD-4.

### **Sheet 7.05**

4. Please provide appropriate WZ for lane configuration of Route 250. The page for the workzone appears to be missing from the plans. (7.08?)

### Drainage

5. Please provide a storm sewer schedule for all structures within VDOT r/w. Please add a note that structure 4' or greater will require ST-1 (steps). Additionally, please provide detail.

We should continue to receive any revised drawings for the above referenced plans even after County approval as some of the changes may affect the right of way and any issued permits. If you have any questions, please call me at (804) 752-4768.

Sincerely,

James Ellis

Land Development Engineer

Robert Butler P.E.

Northern Area Land Use Engineer