



COMMONWEALTH of VIRGINIA

DEPARTMENT OF TRANSPORTATION

RICHMOND DISTRICT
2430 Pine Forest Drive
COLONIAL HEIGHTS, VA 23834
www.VDOT.Virginia.gov

Stephen C. Brich, P.E.
COMMISSIONER

August 27, 2018

Mr. Mike Kennedy
Department of Planning
Henrico County
P.O. Box 90775
Henrico, VA 23273

Re: 2308 Westwood Avenue, Revision 5, New Entrance Location, POD2018-00015

Mr. Kennedy,

VDOT Ashland Land Development has reviewed the above referenced plan dated 8/15/18 and offers the following comments:

1. Please align the entrance edge of pavement along the shoulder with the edge of pavement for the entrance at the radius termination. The entrance radius edge of pavement currently has a 2 foot stub. Either align the pavement radius to terminate at the roadway edge of pavement or add a small taper on the end of the entrance at the end of the pavement radius.
2. The grading at the proposed entrance is somewhat flat and may lead to pooling of stormwater. Please show spot elevations to assure drainage flows off the VDOT roadway and the entrance, into the ditch.
3. Please show spot elevations for the existing and proposed pavement at the joint along the VDOT roadway to assure proper alignment of the pavement surfaces.
4. On sheet C4.5 the entrance appears to be concrete, it should be asphalt to match existing road surface.

VDOT will be happy to meet to discuss comments prior to resubmission. If you have any questions or require any additional information, please do not hesitate to contact me at (804) 585-3586.

Sincerely,

A handwritten signature in black ink, appearing to read "Steve Snell".

Steve Snell, P.E.
Engineer Area Land Use-Ashland Residency