



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewer: Christopher M. Scott, P.E.

POD #: POD2021-00049
Date: 02/26/2021
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: Laurel Park

Plan Review Comments

Comments:

1. The number of accessible parking spaces shown on CA-100 is not sufficient based on Table 1106.1(1) of the 2015 VAUSBC. Ten (10) accessible parking spaces are required where 410 parking spaces are provided.
2. Handicap parking spaces are required to be on the shortest path of travel to an accessible building entrance as required per Section 1106.6. The location of the single handicap accessible parking space does not appear to be near an accessible building entrance.