

**HENRICO COUNTY DPU  
FIRE FLOW ESTIMATE FORM**

ISO (Insurance Service Office) Method of Calculating NFF (Needed Fire Flow)

ENGINEER: \_\_\_\_\_ DATE: \_\_\_\_\_

PROJECT NAME: \_\_\_\_\_ CALC. BY: \_\_\_\_\_

TYPE OF CONSTRUCTION: \_\_\_\_\_

Class of Construction Coef. =  $F$  : \_\_\_\_\_

GROUND FLOOR AREA = \_\_\_\_\_ # of Stories \_\_\_\_\_

Total Floor Area =  $A_i$  (effective area): \_\_\_\_\_

**FIRE AREA CONSIDERED**

Construction Factor  $C_i = 18(F)(A_i)^{0.5}$   
(ROUNDED TO NEAREST 250 GPM)

$C_i =$  \_\_\_\_\_

TYPE OF OCCUPANCY: \_\_\_\_\_

(Worst Case) Occupancy Factor =  $O_i$  : \_\_\_\_\_

EXPOSURE (X) AND COMMUNICATION (P):

$X_1 + P_1 =$  \_\_\_\_\_  $X_4 + P_4 =$  \_\_\_\_\_

$X_2 + P_2 =$  \_\_\_\_\_  $X_5 + P_5 =$  \_\_\_\_\_

$X_3 + P_3 =$  \_\_\_\_\_  $X_6 + P_6 =$  \_\_\_\_\_

$$(X+P)_i = 1.0 + \sum_{i=1}^n (X_i + P_i) =$$

[Max.  $(X + P)_i = 1.75$ ]  
( $n$  = NUMBER OF SIDES OF SUBJECT BUILDING)

**NEEDED FIRE FLOW**

$NFF = (C_i)(O_i)(X+P)_i$

$NFF =$  \_\_\_\_\_

Automatic Sprinklers (YES ☐ NO ☐)

Reduction Factor \_\_\_\_\_ % x NFF = \_\_\_\_\_

**TOTAL:**

Required Fire Flow - Rounded  
(if < 2500 nearest 250)  
(if > 2500 nearest 500)

\_\_\_\_\_ gpm

\* Fire Hydrants Required: \_\_\_\_\_

**I CERTIFY THAT THE ABOVE INFORMATION IS TRUE AND CORRECT.**

SIGNATURE: \_\_\_\_\_ P.E.

\* COMMERCIAL AREA REQUIRES 350 FT. MAXIMUM HOSE LAY.

**References:** NFF CALCULATION PROCEDURE DESCRIBED IN A.W.W.A. M-31, I.S.O.'s 1980 COMMERCIAL FIRE RATING SCHEDULE AND I.S.O.'s 1980 FIRE SUPPRESSION RATING SCHEDULE.