



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Christopher M. Scott, P.E.  
Fax (804) 501-4984

POD #: POD2021-00149  
Date: 04/23/2021  
Code: 2015 VAUSBC  
Phone# (804) 501-4375

Project Description: Highland Park

### **Plan Review Comments**

#### Comments:

1. The number of accessible parking spaces listed on the cover sheet is not sufficient based on Table 1106.1(1). Fifteen (15) handicap accessible parking spaces are required where 609 total parking spaces are provided.
2. Per Section 406.6 of ICC A117.1-2009, curb ramps shall not project into access aisles as shown at the handicap parking space in front of the Trash room in Building 9.