



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2021-00197
Date: 05/28/2021
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: 3500 West View

Plan Review Comments

Comments:

1. The number of accessible parking spaces shown in the Site Data is not sufficient based on Table 1106.1(1) of the 2015 VAUSBC. Ten (10) accessible parking spaces are required where 411 parking spaces are provided.
2. I only counted seven (7) handicap accessible parking spaces on the Master Plan Sheet C-101. Where are the other handicap parking spaces?