



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2021-00240
Date: 07/02/2021
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: Glens at Scott Place Section 3

Plan Review Comments

Comments:

1. The slope of the eastern CG-12 Type C ramp between structures 11 and 12 is greater than the maximum allowable slope. Slopes shall not exceed 1:12 or 8.3%. The slope shown on Sheet C5.1 is 9%.