



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2021-00254
Date: 07/09/2021
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: Cool Lane Apartments

Plan Review Comments

Comments:

1. The number of accessible parking spaces shown in the Site Data does not match what is shown on the plans. Eight handicap parking spaces are shown in the Site Data but six (6) are shown on the plans.
2. Per Section 502.4.1 of the ICC A117.1-2009, van parking spaces that are angled shall have the access aisles located on the passenger side of the parking space. The access aisle for the eastern van parking space cannot be five (5) feet in width if the parking space is less than 11 feet in width.
3. Per Section 502.4.4 of the ICC A117.1-2009, access aisles shall be marked to discourage parking in them. The enhanced finish in the concrete sidewalk that goes through the access aisle of the western van parking space does not appear to be marked to discourage parking.