



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2021-00544
Date: 01/04/2022
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: West Broad Village - Capital Square Office

Plan Review Comments

Comments:

1. Handicap parking spaces are required to be on the shortest path of travel to an accessible building entrance as required per Section 1106.6. Please specify why the two (2) handicap accessible parking spaces on Level 1 in the parking garage are separated from the other handicap accessible spaces.