



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2020-00561
Date: 1/24/2021
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: Woodman Road Self Storage

Plan Review Comments

Comments:

1. Handicap parking spaces are required to be on the shortest path of travel to an accessible building entrance as required per Section 1106.6. The location of the single handicap accessible parking space does not appear to be close to an accessible building entrance. Please verify where the nearest entrance is to the building that would serve this parking space.