



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2022-00099
Date: 03/29/2022
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: Shake Shack at Willow Place

Plan Review Comments

Comments:

1. The number of accessible parking spaces listed in the Site Data needs to be changed to two (2) as shown in the Layout Plan.