



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2022-00188
Date: 05/03/2022
Code: 2015 VAUSBC
Phone# (804) 501-4375

Project Description: New Season Treatment Center at Oakhill Plaza

Plan Review Comments

Comments:

1. Handicap parking sign detail on Sheet C500 does not meet the language requirements per Section 1106.8. The sign needs to contain the following language: PENALTY, \$100-500 FINE, TOW-AWAY ZONE.