



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Christopher M. Scott, P.E.  
Fax (804) 501-4984

POD #: POD2022-00230  
Date: 05/19/2022  
Code: 2015 VAUSBC  
Phone# (804) 501-4375

Project Description: Tuckahoe Park

### **Plan Review Comments**

Comments:

1. The slope around the Restroom Building and the Grandstands of Field M do not meet the maximum allowable slope for walking surfaces per Section 403.3 of ICC A117.1-2009.
2. The slope of the walking surface from the handicap parking spaces to Field G does not meet the maximum allowable slope for walking surfaces per Section 403.3 of ICC A117.1-2009.