



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewer: Christopher M. Scott, P.E.

POD #: POD2022-00343
Date: 07/08/2022
Code: 2018 VAUSBC
Phone# (804) 501-4375

Project Description: QTS East - Phase 3

Plan Review Comments

Comments:

1. The two (2) handicap parking spaces northeast of the building are not on the shortest path to a pedestrian entrance. Handicap parking spaces are required to be on the shortest path of travel to an accessible building entrance as required per Section 1106.6. Those spaces need to be moved south.