



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2022-00381
Date: 07/20/2022
Code: 2018 VAUSBC
Phone# (804) 501-4375

Project Description: Tract 10 Laydown Site

Plan Review Comments

Comments:

1. The trailers are assumed to fall under the construction type VB, the Use Group of either Business or Storage, and will be non-sprinklered. Based on Table 506.2, the total allowable area of a single trailer or a group of trailers cannot exceed 9,000 square feet.
2. The Break Tent is assumed to fall under the construction type VB, the Use Group of A-2, and will be non-sprinklered. Based on Table 506.2, the total allowable area of the tent cannot exceed 6,000 square feet.
3. Based on Table 602, the minimum fire separation distance for a trailer(s) that do not exceed 9,000 square feet and the Break Tent must be 20 feet.