



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Christopher M. Scott, P.E.  
Fax (804) 501-4984

POD #: POD2022-00326  
Date: 07/29/2022  
Code: 2018 VAUSBC  
Phone# (804) 501-4375

Project Description: Electiforce at Drybridge Road

### **Plan Review Comments**

#### Comments:

1. Per Section 1106.6, accessible parking spaces shall be located on the shortest accessible route of travel to an accessible building entrance. Show the location of the accessible entrance on the plans.