



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewer: Christopher M. Scott, P.E.

POD #: POD2022-00146
Date: 08/09/2022
Code: 2018 VAUSBC
Phone# (804) 501-4375

Project Description: 2001 Dabney Road – 3rd Review

Plan Review Comments

Comments:

1. If the location of the handicap parking spaces is only going to be shown on the Architectural sheets, then all the sheets pertaining to the parking garage need to be submitted.
2. The number of handicap accessible parking spaces shown in the Site Data on Sheet C0.00 is eight (8). However, Sheets A2.1a, A2.2a, A2.3a, A2.4a, and A2.5a show nine (9) handicap accessible parking spaces and Level 6 was not even submitted.
3. Doorway (adjacent to the handicap parking space from the top of the page) from the parking garage into the building will not be accessible if a car parks in the parking space directly in front of the door.