



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Christopher M. Scott, P.E.
Fax (804) 501-4984

POD #: POD2022-00424
Date: 09/02/2022
Code: 2018 VAUSBC
Phone# (804) 501-4375

Project Description: Brook Road Knights Inn Apartments

Plan Review Comments

Comments:

1. The CG-12B ramp that serves the western most handicap parking spaces is intersecting the sidewalk that leads to the building.
2. The handrail shown in the Concrete Steps detail does not meet the requirements of Section 505.10.3 of ICC A117.1-2009.
3. Provide CG-12B ramp detail.