



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Christopher M. Scott, P.E.  
Fax (804) 501-4984

POD #: POD2022-00433  
Date: 09/09/2022  
Code: 2018 VAUSBC  
Phone# (804) 501-4375

Project Description: Northstar Academy Phase 1 and Master Plan

### **Plan Review Comments**

#### Comments:

1. Grading of the sidewalk from elevation 242 feet to the front of the landing at the Gym/Multipurpose Building is greater than 1:12 and does not meet the slope requirements of Section 1012.2 for a ramp.