

POD #: POD2021-00465 Date: 09/21/2022 Code: 2018 VAUSBC

Phone# (804) 501-4375

Project Description: Woodspring Suites Extended Stay  $Hotel-2^{nd}$  Review

## Plan Review Comments

## Comments:

1. The Site Data lists the number of van handicap accessible parking spaces provided as two (2), however, Sheet C5.0 calls out one (1) van handicap parking sign. Please confirm how many van handicap accessible parking spaces will be provided and show that on the plans.

2. Provide detail for modified CG-12 Type B ramp.