

Project Description: Warehouse at Lot J

POD #: POD2022-00473

Date: 09/30/2022 Code: 2018 VAUSBC Phone# (804) 501-4375

## Plan Review Comments

## Comments:

1. Per Section 1106.5, for every six (6) or fraction of six (6) accessible parking spaces, at least one shall be a van-accessible parking space. Three (3) van-accessible parking spaces are required where there are 14 accessible parking spaces provided. The Site Data lists two (2) van-accessible parking spaces and only two (2) are marked as van-accessible on the Site Plans.