



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Christopher M. Scott, P.E.  
Fax (804) 501-4984

POD #: POD2022-00624  
Date: 12/30/2022  
Code: 2018 VAUSBC  
Phone# (804) 501-4375

Project Description: Pointe at Twin Hickory Phase 2

### **Plan Review Comments**

#### Comments:

1. Per Section 502.4 of ICC A117.1-2009, handicap van and car spaces are required to have an adjacent access aisle. Two handicap parking spaces do not have an access aisle.
2. Provide a handicap parking sign detail.