



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: **Erin Towler, Plan Reviewer**
Email: tow053@henrico.us

POD #: **POD2023-00317**
Date: 8/11/2023
Code: 2018 VCC
Phone# **(804) 501-4811**

Project Description: **Willow Lawn Shopping Center – Five Below**

POD Review

- 1) The new retail space wall abuts the existing restaurant wall, be sure to comply with the fire separation requirements based on the building use and construction type.
- 2) Make sure the ramp and retaining wall design is permitted.