



County of Henrico, Virginia  
Office of Building Construction and Inspections  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: **Erin Towler, Plan Reviewer**  
Email: tow053@henrico.us

POD #: **POD2023-00350**  
Date: 8/18/2023  
Code: 2018 VCC  
Phone# **(804) 501-4811**

Project Description: **Blossman Gas AutoGas Infrastructure**

### **POD Review Comments**

- 1) The 1990-gallon LP tank shall have a separation distance of 25 feet minimum from important buildings or the property line, pursuant to the Virginia Fuel and Gas Code Sec. 401.2 and NFPA 58 Table 6.4.1.1.
- 2) A building permit is required for all retaining walls supporting three feet or more of unbalanced fill, in accordance with Virginia Construction Code Sec. 108.2 (7). Design shall conform to VCC Sec. 1807.2. Pedestrian guards are required where any walking surface is located more than 30-inches above the grade below, per VCC Sec. 1015.

These comments are for the applicant's information and do not require resubmission.