



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: **Erin Towler, Plan Reviewer**
Email: tow053@henrico.us

POD #: **POD2022-00349**
Date: 8/23/2023
Code: 2018 VCC
Phone# **(804) 501-4811**

Project Description: **Gayton Village**

POD Review Comments

- 1) In accordance with Table 1106.1(2) of the Virginia Construction Code, a minimum of 6 accessible parking spaces shall be provided, given that there are 153 parking spaces.

These comments are for the applicant's information and do not require resubmission.