



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Erin Towler, Plan Reviewer
Email: tow053@henrico.us

POD #: **POD2022-00282**
Date: 8/23/2023
Code: 2018 VCC
Phone# (804) 501-4811

Project Description: **Back to Life Towing**

POD Review Comments

- 1) In accordance with the Section 108.2 of the Virginia Construction Code, a building permit is required for installation of the 288 square foot storage building.

This comment is for the applicant's information and does not require resubmission.