



County of Henrico, Virginia  
**Office of Building Construction and Inspections**  
P.O. Box 90775 Henrico, Virginia 23273  
Reviewed by: Erin Towler, Plan Reviewer  
Email: tow053@henrico.us

POD #: **POD2022-00378**  
Date: 8/29/2023  
Code: 2018 VCC  
Phone# (804) 501-4811

Project Description: **Metromont Corporation - Revised Bay and Tool Room Addition**

**POD Review Comments**

- 1) In compliance with Virginia Construction Code, Section 1106.1, a minimum of 4 accessible parking spaces are required, given that there are a total of 96 parking spaces provided.

This comment is for the applicant's information and does not require resubmission.