



County of Henrico, Virginia
Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Erin Towler, Plan Reviewer
Email: tow053@henrico.us

POD #: **POD2022-00381**
Date: 8/31/2023
Code: 2018 VCC
Phone# (804) 501-4811

Project Description: **RRFG Expansion**

POD Review Comments

- 1) Where parking is provided, accessible handicap parking spaces shall be provided in compliance with Virginia Construction Code, Section 1106.1. Per Table 1106.1(1) & 1106.1(2), a minimum of *3 accessible* parking spaces are required, given that there are a total of *67 total* parking spaces provided.

This comment is for the applicant's information and does not require resubmission.