

September 11, 2023

David Ellington, PE
Kimley-Horn and Associates, Inc.
1700 Willow Lawn Drive, Suite 200
Richmond, VA 23230

RE: West Village
12120 W Broad Street
File No: 5558; POD2023-00275
DWG FILE: 2023-025

Dear Ellington:

We have reviewed the revision to the approved construction plans submitted to the Planning Department on August 24, 2023.


Please address the following comments and **resubmit revised construction plans** for review.

CU-301:

1. No drop connections are allowed at the MMH. Raise the drop connection at MH-13 to remove the additional drop connection at the MMH-5.

If you have any questions concerning the above noted comments or the plans, please contact me at 501-4508 or John Yi at 501-4511.

Sincerely,



Alice Thompson
Utilities Engineer

cc: Brian McNeal, SKM LLC

bc: Ralph Claytor
Marchelle Sossong
Michael Aust, DPW
Daniel Ivy
Aimee Crady, Planning

ANT/vr

REVISED CONSTRUCTION PLANS REQUIRED