

County of Henrico, Virginia

Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Erin Towler, Plan Reviewer

Email: tow053@henrico.us

POD #: **POD2023-00476**

Date: 10/27/2023 Code: 2018 VCC

Phone# (804) 501-4811

Project Description: Park N' Go Phase IV - Expanded

POD Review Comments

1) Where parking is provided, accessible handicap parking spaces shall be provided in compliance with Virginia Construction Code, Section 1106.1. Where more than one parking facility is provided on a site, the number of parking spaces required to be accessible shall be calculated separately for each parking facility. Therefore, for this Phase IV parking area, given there are a total of 210 parking spaces provided, a minimum of 8 accessible parking spaces are required.