

POD #: **POD2023-00496**

Phone# (804) 501-4811

Date: 11/15/2023

Code: 2018 VCC

County of Henrico, Virginia

Office of Building Construction and Inspections
P.O. Box 90775 Henrico, Virginia 23273
Reviewed by: Erin Towler, Plan Reviewer

Email: tow053@henrico.us

Project Description: Best Value Inn Renovations

POD Review Comments

1) Where parking is provided, accessible parking spaces shall be provided in compliance with Virginia Construction Code, Section 1106.1. Where more than one parking facility is provided on a site, the number of parking spaces required to be accessible shall be calculated separately for each parking facility. Please tabulate the number of total and accessible parking spaces provided to demonstrate compliance.