

December 13, 2023

Nisit Sapparkhao, PE
Infinity Engineering Group
1208 E. Kennedy Blvd, Suite 230
Tampa, FL 33602

**RE: Bank of America – Willow Lawn
5000 W. Broad St.
POD NO: 2023-00121**

Dear Mr. Sapparkhao:

We have reviewed the construction plans submitted to the Planning Department on November 28, 2023.

Please address the following comments and **resubmit revised construction plans** for review. Water and Sewer Agreements that must be executed by the Owner and the County for water and sewer improvements **have not** been executed.

General:


1. Agreements have been sent back to the owner for revision.

Utility Plan:

2. Provide a sanitary sewer profile of the 8" DI. Show all crossings, angles, manhole inverts, and slopes on the profile.

If you have any questions concerning the above noted comments or the plans, please contact me at 501-4992 or Alice Thompson at 501-4805.

Sincerely



Nolan Ekers
Utilities Engineer

cc: Stephen Hruska, 5000 Richmond, LLC

bc: Ralph Claytor
Marchelle Sossong
Mike Aust, DPW
Daniel Ivy
Todd Rigler, Planning

NBE/djm

REVISED CONSTRUCTION PLANS REQUIRED